

# Water Utility Services, Inc.

P.O. Box 2628  
Spring, Texas 77383  
281-290-0704

Client: City of Sweeny  
102 W. Ashley Wilson Rd.  
Sweeny, TX 77480  
Lindsay Koskiniemi

## Test Report

PROJECT LOCATION: City of Sweeny  
SAMPLE TYPE: Grab  
COLLECTION DATE: 3/8/2023

COLLECTED BY: JG  
SAMPLE MATRIX: Potable Water

SAMPLE LOCATION	Iron mg/L	Manganese mg/L	Iron Related Bacteria
508 2nd Street Outside	< 0.10	0.070	negative
508 2nd Street Inside	< 0.10	0.060	negative
1111 Alice Outside	< 0.10	0.086	negative
1111 Alice Inside	< 0.10	0.072	negative
109 Ballard Outside	0.36	0.553	negative
109 Ballard Inside	0.15	0.312	negative
1664 1/2 N. Main Outside	< 0.10	0.061	negative
1664 1/2 N. Main other side	< 0.10	0.035	negative

Method:	Hach 8008	Hach 8149	BART
Analyst:	SG	SG	SG
Date:	3/8/2023	3/8/2023	3/8/2023

**Steve Grychka**

---

Steve Grychka  
Laboratory Director